



May 8, 2026

Addendum #2 - IFB 26-014 Myers WTP Electrical Query Project

Prospective Bidders:

The above solicitation is amended as set forth below; bidders **MUST** acknowledge receipt of this addendum. **Please sign & return this form with your sealed bid.**

1. Question: Is a bypass required for the drive?
Answer: Yes, a bypass is required on each drive.

2. Bid due date has been changed to 10:30 am on May 28, 2026.

Printed Name

Date

Signature

Email Address

Company Name

Telephone Number

Company Address

City, State, Zip



 Joyce Sawyer, Buyer II
 Board of Water and Sewer Commissioners