



June 2, 2023

Addendum #1 - IFB 23-030 Hillcrest Replacement Pumps Purchase

The above solicitation is amended as set forth below; bidders MUST acknowledge receipt of this addendum.

- Answers to questions/comments received:
 1. Question 1: Paragraph 2.5 I2 states the electric motors need to be INVERTER DUTY. The existing pumps and these new pumps are constant speed, not variable speed operation; therefore, please confirm if this is correct.

Answer to Question 1: Please provide standard motor in lieu of inverter duty since VFDs will not be installed at this time.

2. Question 2: The data sheet of the existing motors indicates the motors have 120VAC space heaters and VPI 1000 winding treatment, yet specifications (2.5 I) do not request these additional features. Please confirm if this is correct.

Answer to Question 2: Motor winding insulation to be VPI 1000. (Same as existing pumps) Motors to be provided with 120VAC space heaters. (Same as existing pumps).

***Please note that the due date for this bid has not changed. Bids are due by 10:30 am on June 7, 2023**

Printed Name

Date

Signature


Email Address

Company Name

Telephone Number

Company Address

City, State, Zip



Joyce Sawyer, Boyer II
Board of Water and Sewer Commissioners