

January 5, 2024

Addendum #1 - IFB 24-002 Turbine Pump Repair at Wright Smith

Prospective Bidders:

The above solicitation is amended as set forth below; bidders <u>MUST</u> acknowledge receipt of this addendum. <u>Please sign & return this form with your sealed bid</u>.

Please review the following changes:

- 1. Page 3 Scope of Work
 - A. Change 5th bullet point from: ASSEMBLE PUMP BACK TO FACTORY SPECS

Replace with:

ASSEMBLE PUMP BACK TO FACTORY SPECS WITH NEW BOWL ASSEMBLY

- B. Add additional bullet point to read:
 INSTALL NEW BOWL ASSEMBLY THAT MAWSS WILL PROVIDE
- 2. Page 3 Alternate Bid
 - A. Change: REPLACE BOWL ASSEMBLY

Replace with:

REPLACE/INSTALL BOWL ASSEMBLY THAT CONTRACTOR WILL PROVIDE

B. Change the beginning of the **Note** from:

Note: Alternate bid is for the replacement of the bowl assembly

Replace with:

Note: Alternate bid is for the replacement of the bowl assembly that the contractor will purchase

- 3. Page 8 Bid Sheet
 - A. Change Primary Bid Without Bowl Assembly Replacement

Replace with: Primary Bid – Bowl Assembly Will be Provided by MAWSS

B. Change <u>Alternate Bid</u> – Includes Bowl Assembly Replacement

Replace with: Alternate Bid – Bowl Assembly Will be Provided by Contractor

Please replace pages 3 & 8 of the original IFB 24-002 with the attached pages that includes all changes listed above.

Note: Sealed bids are due by 10:30 am on January 16, 2024.

Printed Name	 Date
Signature	Email Address
Company Name	Telephone Number
Company Address	City, State, Zip
	Joyce Sawyer, Boyer II Board of Water and Sewer Commissioners

IFB 24-002 TURBINE PUMP REPAIR SUMMARY AND SCOPE

Summary of Work

For Rebuild of the Trickling Filter Recycle Pump #1 at the Wright Smith Jr. WWTP

Scope of Work

The following services shall be provided for one (1) 14" Peerless Vertical Turbine Pump:

- SANDBLAST ALL PARTS
- REPLACE 1 ½ " by 105 ½ " PUMP SHAFT 416ss
- REPLACE STUFFING BOX
- REPLACE STUFFING BOX BUSHING (BRONZE)
- INSTALL NEW BOWL ASSEMBLY THAT <u>MAWSS WILL PROVIDE</u>
- ASSEMBLE PUMP BACK TO FACTORY SPECS WITH NEW BOWL ASSEMBLY
- SUPPLY NEW CHESTERTON SPLIT SEAL FOR THE DISCHARGE HEAD OF PUMP

Miscellaneous

- 1. All bolts, nuts and washers shall be replaced with new 316 Stainless Steel.
- 2. All outside Columns and Suction bowl shall be coated with a Coal Tar Epoxy.
- 3. All above ground pump shall be coated with a Rustic Brown Industrial Epoxy Paint.
- 4. Inside pump columns, suction bowl and discharge head shall be coated with Belzona 5811.
- 5. Transportation **MUST** be provided by successful bidder and **MUST** be included in the bid price.
- 6. Successful bidder **MUST** provide a **two-year warranty** on all workmanship and materials outside of normal wear and tear.
- 7. Successful bidder **MUST** pick up pump from the Wright-Smith WWTP at 1879 N. Conception Street Rd.

ALTERNATE BID:

REPLACE/INSTALL BOWL ASSEMBLY THAT CONTRACTOR WILL PROVIDE (SHAFT COUPLING, IMPELLER, TRUST RING, THRUST RING RETAINER, IMPELLER KEY, THREADED BEARING, DISCHARGE BOWL, BOWL AND BELL BEARINGS, BELL, SAND COLLAR, 316ss BOLTS)

Note: Alternate bid is for the replacement of the bowl assembly that the contractor will purchase, in addition to the above listed requirements under "Scope of Work" & "Miscellaneous."

END OF SUMMARY AND SCOPE

IFB 24-002 TURBINE PUMP REPAIR BID SHEET

Primary Bid – Bowl Assembly Will be Provided by MAWSS

Total Cost*	\$	
*Must include all charges		
Warranty**		
**Minimum required: 2-year	parts & labor	
Lead Time (ARO) (After receipt of order)		
<u>Alte</u>	rnate Bid – Bowl Assembly W	ill be Provided by Contractor
Total Cost*	\$	
*Must include all charges		
Warranty**		
**Minimum required: 2-year	parts & labor	
Lead Time (ARO)		
(After receipt of order)		
Company Name		Payment Terms
		-
Address		
City, State, Zip		
Submitted By		Title
	Please Print	_
Phone	Email Address	
		Please Print
The signer declares under penaltrall of the terms and conditions of		sign this document and bind the company or organization to the
Signature		Date