



April 2, 2026

**Addendum #1 - IFB 26-015 SRF Gaillard Pump Station Conex Boxes**

Prospective Bidders:

The above solicitation is amended as set forth below; bidders **MUST** acknowledge receipt of this addendum. **Please sign & return this form with your sealed bid.**

Please review the following changes/updates:

Questions or comments received from prospective bidder.

1. Will any shop drawings of the said container or containers be required?

Response: Shop drawings for individual containers are not required. General drawing showing container overall dimensions and internal clear dimensions are required.

2. Will any calculations for structural reinforcement?

Response: If no structural modifications are made to the provided units, calculations are not required.

3. Will quality assurance documentation be required?

Response: Quality assurance documentation not required. Please provide any available documentation from the manufacturer.

4. Will operation and maintenance manuals be required?

Response: Operation and Maintenance manuals are not required.

5. Is a 90 day warranty for the units structural integrity sufficient?

Response: 2 years is the standard MAWSS warranty period on anything that isn't covered by a manufacturer's warranty. Units must be warrantied following MAWSS standards.

6. Will a warranty be required for the painting and/or coating system?

Response: 2 years is the standard MAWSS warranty period on anything that isn't covered by a manufacturer's warranty. Paint must be warrantied following MAWSS standards and be provided as specified.

7. The container will be within the size specifications as needed. Will logs showing the history of a used container be required?

Response: Logs showing the history of the containers are not required. MAWSS reserves the right to reject used units showing excessive wear and defects.

8. The container will not have a factory coated interior floor. Is a Marine Grade Plywood floor acceptable?

Response: Steel subfloor with Marine Grade Plywood interior floor is acceptable.

9. Is ventilation of each unit required?

Response: Ventilation will not be required.

10. There could possibly be minor denting and scratching of the paint as is common with a one-trip container. This will not be repaired; it would be touched up only. Is this acceptable?

Response: Painting and touch up of minor defects is allowable. MAWSS reserves the right to reject used units showing excessive wear and defects.

11. We will only deliver and place the containers on the items you have available as close as we can. There will be no one onsite to inspect or ensure proper functionality. This would be left to the end user. Is this acceptable?

Response: MAWSS will provide prepared locations for the containers to be placed. MAWSS reserves the right to reject used units with defects including doors and hinges that do not function properly.

12. Bid due date has been changed to 10:30 am on April 16, 2026.

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature

\_\_\_\_\_  
Email Address

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Telephone Number

\_\_\_\_\_  
Company Address

\_\_\_\_\_  
City, State, Zip

  
Joyce Sawyer, Mayor II  
Board of Water and Sewer Commissioners