



February 16, 2024

**Addendum #2 - IFB 24-007 Roof Replacement Myers WTP**

Prospective Bidders:

The above solicitation is amended as set forth below; bidders **MUST** acknowledge receipt of this addendum. **Please sign & return this form with your sealed bid.**

Please review the following information and answers to questions received:

1. Will alternate manufacturers providing 60 mil nominal membranes be accepted? **No, please refer to specification 07 54 19 2.03 A. 1. A. i. & ii. for membrane thickness requirements.**
2. Do all components such as liquid flashings, edge metals, insulation and coverboard have to be warranted by the membrane manufacturer? **Yes, separate warranties will not be accepted. All components will have to be specifically listed on the manufacturer’s warranty.**
3. Can we use segmented copings at the buildings curved corners? **No, Radius copings must be provided**
4. Will you require ANSI SPRI ES-1 uplift testing for the radius portion of the copings? **Yes, testing must be provided to show compliance with IBC and ASNI SPRI ES-1**
5. Do we have to meet the uplift pressures for each zone or will you allow prescriptive enhancements in zone 3? **No, you must provide an uplift test in accordance with FM 4474 for each zone. Refer to 07 54 19 1.11 A. 1. for clarification.**

\_\_\_\_\_  
Printed Name

\_\_\_\_\_  
Date

\_\_\_\_\_  
Signature


\_\_\_\_\_  
Email Address

\_\_\_\_\_  
Company Name

\_\_\_\_\_  
Telephone Number

\_\_\_\_\_  
Company Address

\_\_\_\_\_  
City, State, Zip

  
\_\_\_\_\_  
Joyce Sawyer, Buyer II  
Board of Water and Sewer Commissioners