



January 12, 2026

Addendum #3 - IFB 25-058 SRF Gaillard Bypass Pumps Purchase

Prospective Bidders:

The above solicitation is amended as set forth below; bidders **MUST** acknowledge receipt of this addendum. **Please sign & return this form with your sealed bid.**

Please review the following changes/updates:

Questions received from prospective bidder:

1. Please confirm that a GC License or DBE will not be required in regard to SRF funds being used for this project.

Response: A GC License will not be required, and DBE solicitation is not required.

2. Will a scrubber be required to prevent discharge from venturi?

Response: No

3. Will there need to be a discharge permit issued for pump testing?

Response: No

4. Will these pumps need to meet the MAWSS specifications for Bypass pumps? (Specifications for wastewater bypass pumps)

Response: The bid package specifications supersede the MAWSS standard specifications.

5. Since we have had chipping in the corners with powder coated pumps, we request Marine Grade paint be accepted.

Response: Equivalents and exceptions are not approved before bid receipt.

6. We request that 24v system be accepted. 12v is specified.

Response: Equivalents and exceptions are not approved before bid receipt

Printed Name

Date

Signature

Email Address

Company Name

Telephone Number

Company Address

City, State, Zip


Joyce Sawyer, Buyer II
Board of Water and Sewer Commissioners
