

MAWSS HIGHWAY 90 CROSSING WATER MAIN REPLACEMENT
PROJECT NO. 017642004
PRE BID DATE: SEPTEMBER 23, 2025
BID DATE: OCTOBER 6, 2025
ADDENDUM NO. 2
DATE: OCTOBER 1, 2025

TO ALL BIDDERS ON THE ABOVE REFERENCED PROJECT:

This Addendum forms a part of the CONTRACT DOCUMENTS and modifies the original Bidding Documents dated August 2025 and Addendum No. 1, as noted below. Acknowledge receipt of this Addendum in the space provided in the PROPOSAL. Failure to do so may subject the Bidder to disqualification. Attach Addendum No. 2 in its entirety to the submitted Bid. Bids received without Addendum No. 2 and all attachments may be subject to disqualifications.

This Addendum consists of 2 pages.

CHANGES TO SPECIFICATIONS:

PROJECT SPECIFICATIONS, PROPOSAL

1. Revise Proposal – Supplier Diversity Policy (SDP) Acknowledgement
 - a. **Delete from Addendum No. 1.** This form is not required for this project.
2. Revise Proposal – Subcontracting Plan/Good Faith Effort
 - a. **Delete from Addendum No. 1.** This form is not required for this project.
3. Revise Proposal – Supplier Diversity 16-01 MAWSS Disadvantage Business Enterprise Policy For Public Works Act Contracts
 - a. **Delete from Addendum No. 1.** This form is not required for this project.

PROJECT SPECIFICATIONS, SPECIAL PROVISIONS

1. Revise Special Provisions Section 10.43 – Basis of Payment for Base Bid, delete pay item WL-1 in its entirety and replace with the following:

“WL-1 20” Ductile Iron Water Main Line Pipe (Restrained Joint) (Zinc Coated Carrier Pipe), Class 250, Open Cut Installation: The unit price bid for this pay item shall be compensation in full for furnishing all material, labor, equipment, and incidentals (including restrained joints with Fast Grip Gaskets or approved equal) necessary to install one (1) linear foot (LF) of Ductile Iron Class 250 pipe complete in place and in accordance with the plans and standard specifications. The exterior of all ductile iron pipe installed shall be zinc coated. Measurement for payment will be made along the centerline of installed pipe, such measurement starting at the centerline of installed pipe and terminating at the centerline of junctions or to the various ends. There will be no deductions in measured length for specials, fittings, or valves installed in the line.”

2. Revise Special Provisions Section 10.43 – Basis of Payment for Base Bid, delete pay item WL-1A in its entirety and replace with the following:

“WL-1A 20” Ductile Iron Water Main Line Pipe (Restrained Joint) (Zinc Coated Carrier Pipe), Class 350, Installation Auger Bore Installation:

The unit price bid for this pay item shall be compensation in full for furnishing all material, labor, equipment, and incidentals (including restrained joints with Fast Grip Gaskets or approved equal) necessary to install one (1) linear foot (LF) of Ductile Iron Class 350 carrier pipe within the auger bore steel casing, complete in place and in accordance with the plans and standard specifications. The steel encasement pipe installed by auger bore will be paid for under a separate pay item. The exterior of all installed ductile iron pipe shall be zinc coated. Measurement for payment will be made along the centerline of installed pipe, such measurement starting at the centerline of installed pipe and terminating at the centerline of junctions or to the various ends. There will be no deductions in measured length for specials, fittings, or valves installed in the line.”

CLARIFICATIONS:

1. Per MAWSS and in accordance with SRF requirements, the documents listed below are no longer required to be submitted with the Bid Documents. However, if any of these forms are submitted as part of the bid package, they will be disregarded and excluded from the final Contract execution.
 - MAWSS Forms added per Addendum No. 1 to be omitted:
 - **Supplier Diversity Policy (SDP) Acknowledgement (Not Required)**
 - **Subcontracting Plan/Good Faith Effort (Not Required)**
 - **Supplier Diversity 16-01 MAWSS DBE Policy (Not Required)**
2. For clarification purposes, the Subcontracting Plan included in the original Bid Documents is to remain and to be completed and submitted with the Bid.

++ END OF ADDENDUM ++